



Boston

April 4, 2012

Mr. Hank Voorvaart
The City Master Box Div
Alarm Applications, Inc.
PO Box 297
Colchester CT 06415

After review and bench testing for compatibility with the Boston Fire Department's municipal alarm system, Commissioner Roderick Fraser has authorized the use of Alarm Applications "Master Box" for use for indoor applications. This approval covers the transmission of the fire box number to Fire Alarm only. BFD Fire Alarm does not provide monitoring of trouble or supervisory conditions nor does this approval allow for this to occur with the electronic boxes

The Boston Fire Department does not endorse individual products or devices. This approval authorizes the use of the "Master Box" product to connect to the City of Boston municipal alarm system only. The approval is solely for this device. Any other products you or competitors wish to submit in the future will require individual review and approval for each product.

Sincerely,

A handwritten signature in black ink, appearing to read "Barry Shea", is written over a faint, circular official seal of the Boston Fire Department.

Deputy Chief /Fire Marshal
Fire Prevention Division
Boston Fire Department
1010 Mass Ave. Boston Ma. 02118



Thomas M. Menino, Mayor/FIRE DEPARTMENT/115 Southampton Street 02118

Printed on recycled paper

01-12-01

Kingfisher Company, inc.
81 Old Ferry Road
Lowell, Massachusetts 01854

Phone: (978) 596-0214
Fax: (978) 596-0217

Email: Info@kfc.com

Website: www.kfci.com



Kingfisher Company, inc.



Kingfisher Company, inc.
81 Old Ferry Road
Lowell, Massachusetts 01854
Email: Info@kfc.com

Phone: (978) 596-0214
Fax: (978) 596-0217

Website: www.kfc.com