



Kingfisher Company, inc.

ELECTRONIC MASTER BOX TECHNICAL BULLETIN 02

EARTH GROUND RETURN (E.G.R.) PROGRAMMING

In the software programming section for Edit Transmitter Level Attributes in Line Selection Item No. 4 the E.G.R. is Municipal/Summoning should be set for Summoning. If the E.G.R. is set for Municipal the timing between digits will be too long.

For additional technical support please contact the manufacturer as follows.

Kingfisher Company, inc.

81 Old Ferry Road
Lowell, MA 01854
978-596-0214
info@kfc.com
www.kfc.com

Kingfisher Company, inc., products must be used within their published specifications and must be PROPERLY specified, applied, installed, operated, maintained and operationally tested in accordance with their installation instructions at the time of installation and at least twice a year or more often and in accordance with local, state and federal codes, regulations and laws. Specification, application, installation, operation, maintenance and testing must be performed by qualified personnel for proper operation in accordance with all of the latest National Fire Protection Association (NFPA), Underwriters' Laboratories (UL), National Electrical Code (NEC), Occupational Safety and Health Administration (OSHA), local, state, county, province, district, federal and other applicable building and fire standards, guidelines, regulations, laws and codes including, but not limited to, all appendices and amendments and the requirements of the local authority having jurisdiction (AHJ).

NOTE: Due to continuous development of our products, specifications and offerings are subject to change without notice in accordance with Kingfisher Company, inc., standard terms and conditions

Kingfisher Company, inc. 81 Old Ferry Road - Lowell, MA 01854
Phone: 978-596-0214 Fax: 978-596-0217 www.kfc.com